# MPM416W Submersible

# **Level Transmitter**




#### **Features**

- Separate construction; full sealed stainless steel construction for submersible/inserted sensor; aluminumalloy electric connection box; easy for installation, wiring and calibration;
- Explosion-proof version product conforms to Exia II CT6 of Standard GB3836.4; Explosion-proof Certificate is issued
- Ship-use product conforms to CCS Rules of Classification of Sea-going Steel Ships(2006); Ship-use Product Certificate is issued:
- **CE** Certificate

#### Introduction

MPM416W Submersible Level Transmitters use high performance piezoresistive pressure sensor as sensing elements. It measures liquid static pressure accurately which is positive proportional to liquid depth, transmitting pressure signal into standard current/ voltage output signal by amplifier circuit board. The product has high accuracy, compact size and easy operation characteristics, and it can be submersible into the liquid to measure level from transmitter bottom to liquid surface. It is widely used for the liquid measure and control of both petroleum, chemi-industry, power station, city water supply and drainage and hydrology.

#### **Load Characteristic**



2-wire

4mA~20mADC output

15V~30VDC power supply


$$R_{L} \leq \frac{U_{n} - 15V}{20mA} \times 10^{3} \left(\Omega\right)$$

# **Specifications**


Pressure range	1, 2, 5, 10, 20, 50, 100, 200mH <sub>2</sub> O							
Overpressure	1.5times FS							
Accuracy	<u>+</u> 0.25%FS(typ.) <u>+</u> 0.5%FS(max.)							
Stability error	<u>+</u> 0.1%FS(typ.)	<u>+</u> 0.2%FS(max.)	pressure range>1	0mH₂O				
	±10mmH <sub>2</sub> O(typ.)	±20mmH <sub>2</sub> O(max.) pressure range≤10mH <sub>2</sub> O						
Temp. drift		Zero drift	: <u>,+</u> %FS/°C	Sensitivitydrift, <u>+</u> %FS/°C				
	Range>10mH <sub>2</sub> O	0.005(typ.)	0.01(max.)	0.02(max.)				
	Range ≤10mH <sub>2</sub> O	0.01(typ.)	0.02(max.)	0.02(max.)				
	Range ≤5mH <sub>2</sub> O	0.015(typ.)	0.03(max.)	0.02(max.)				
	Range ≤2mH <sub>2</sub> O	0.025(typ.)	0.05(max.)	0.02(max.)				
Transmitting	2-v	vire	3-wire	3-wire				
Power supply	15~28VDC(Intrinsic safe version is supplied through safe barrier)							
Output signal	4~20r	mADC	0~10/20mADC	0/1~5/10VDC				
Load(Ω)	<(U-15	i)/0.02A	<(U-15)/0.02A	>5k				
Material contacting with media	Housing: stainless s	steel 1Cr18Ni9Ti	O-ring: Viton					
	Diaphragm: stainles	s steel 316L	Rubber casing: NBR					
	Cable: Ф7.2mm PVC/Polyurethane cable with vented tube							
Operation temp.	-30°C ~80°C -10°C ~70°C -10°C ~60°C							
Storage temp.	-40°C ~120°C −20°C ~85°C							
Protection	IP68(sensor part), IP65(wiring part)							
Ex-proof class	Exia II CT6							

# Outline Construction (Unit: mm)

### Outline dimension




Outline and Installation Dimension of Electric Housing




# **Electrical Connection**

Terminal connection in Electrical Housing




Cur	rent	Voltage		
Terminal	Definition	Terminal	Definition	
+/A	V+	+/A	V+	
-/B	10	-/B	OUT	
		ΑJ	GND	


## **Application Example**




Connecting level transmitter with measure displayer to build up one measure and control system.




Connecting Ex-proof version transmitter with safe barrier and measure displayer to build up measure and control system;



When measure static level in open tank, put level transmitter into tank bottom, and fix transmitter cable and connection box at the open tank entrance.




Connecting with MSB9418 measure displayer to build up one liquid measure and control system with upper and lower limits alarming. Meanwhile, the displayer could output RS232 or analog signal 1V~5VDC, 0V~5VDC, 4mA~20mADC.




1#transmitter 2#transmitter


Connecting the most two level transmitter with MSB9438 measure displayer to build up one level difference system with multi-channel display. It can also output 4mA~20mADC analog output and provide upper and lower limit alarming and control.




When measuring flow water, insert one steel tube Φ45 which has little holes Φ5 at different heights. Make holes opposite to water flowing direction, and let water go into the tube and fix cable and connection box at the entrance of tube.


### Installation at Local Place (Unit: mm)








ChartA (user decide)



ChartB (Enclosed by factory or user decide)



ChartA (user decide)

#### **Order Guide**

MPM4	-16W	Submersible Level Transmitter								
		Range(mH <sub>2</sub> O)	[0~X mH <sub>2</sub> O]L	L: cable length, suggested: L-X=(1~2)m						
			Output signal							
			E	4~20mADC						
			F 1~5VDC							
			J 0~5VDC							
			Q	0~10mADC 0~20mADC 0~10VDC						
			U							
			V							
				Code		Construction material				
				Code	Diap	hragm	Pressure port	Housing		
				22	SS	316L SS		SS		
				25	Tan	talum	SS	SS		
					Code	Others				
					$M_1$	0~100% hand pointer indicator				
		i Ir			Intrinsic	Intrinsic safe version Exia II CT6				
					C <sub>1</sub> M20×1.5 male, face type seal			seal		
				C <sub>3</sub> G1/2 male			ale			
					C <sub>5</sub>	M20×1.5 male, waterline seal				
					Т	Ship-use				
					F <sub>1</sub>	Fixed fla	ange			
1401616			_							
MPM41	MPM416W [0~3mH <sub>2</sub> C		E	22	iC <sub>1</sub>	1	the whole spec			

#### **Notes**

- 1.Please pay attention if the media is compatible with contacting material, especially pay attention to media density at measuring situation (except water);
- 2. We provide the user with PVC or polyurethane cable; polyurethane cable is more flexible and wearable. If the user has no special requirements, the default would be PVC cable;
- 3.If the product is installed in lightning and thunder area, please note "lightning Protection" in the order; we suggest to use lightning protection device to make sure power is grounding safely;
- 4.If the user has special requirement, please feel free to contact with our company.

MICROSENSOR